



Laclede County R-1 Schools
CONWAY
"Home of the Bears"

*Superintendent: Mr. Matt Searson
HS Principal: Mrs. Kathryn Taylor
JH Principal: Dr. Ericka Armstrong
Elem. Principal: Mrs. Shelly Dill
Special Svcs.: Ms. Cristen Hartman*

726 West Jefferson Ave. Conway, MO 65632

Phone: 417-589-2951

Lead Testing Initial Results

The Laclede County R-1 School District received our initial lead testing results on Saturday, December 9, 2023. Testing was conducted on fixtures used for drinking or food preparation.

Testing Criteria:

Each sample was tested for total lead content which includes dissolved and particulate. The elevated level is defined as a level of lead at or above 5 parts per billion. Sampling was conducted per EPA test guidelines by initial draw after stagnation (periods of non-use that exceed eight hours). This manner of testing is the first step in localization and is paired with follow-up flush testing to further localize the source of any elevated levels.

Explanation of results:

Total test points sampled - 96

Total samples above the action level of 5 parts per billion – 4

Immediate actions:

In accordance with guidance from the EPA, the affected fixtures have been temporarily turned off while we await the arrival of lead reducing filters.

Next steps:

Once remediation steps have been completed, follow up flush samples will be collected per EPA and DHSS testing guidelines.



Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

December 09, 2023

Matthew Searson
Laclede County R-1 SD
726 W. Jefferson
Conway, MO 65632 RE:

Drinking Water Lead

Dear Matthew Searson:

Please find enclosed the analytical results for the **96** sample(s) the laboratory received on **11/22/23 2:45 pm** and logged in under work order **GK04047**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read "Chenise Lambert-Sykes".

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com



Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

SAMPLE RECEIPT CHECK LIST

Items not applicable will be marked as in compliance

Work Order GK04047

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
YES	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

Sample: GK04047-01
Name: WF CARDOSO - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:07
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 16:25	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-02
Name: WF CARDOSO - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:08
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 16:27	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-03
Name: WF COCHRANE - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:10
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 16:28	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-04
Name: WF COCHRANE - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:12
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 16:30	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GK04047-05
Name: BF COCHRANE - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:14
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 16:32	KMC	EPA 200.8 REV 5.4

Sample: GK04047-06
Name: BF COCHRANE - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:12
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 16:33	KMC	EPA 200.8 REV 5.4

Sample: GK04047-07
Name: WF BRADLEY - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:15
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.68	ug/L		12/05/23 11:24	1	1.00	12/05/23 16:38	KMC	EPA 200.8 REV 5.4

Sample: GK04047-08
Name: WF BRADLEY - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:16
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.19	ug/L		12/05/23 11:24	1	1.00	12/05/23 16:39	KMC	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: GK04047-09
Name: TEACHER WORK ROOM SINK - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:23
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.33	ug/L		12/05/23 11:24	1	1.00	12/05/23 16:41	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-10
Name: TEACHER WORK ROOM SINK - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:24
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 10:25	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-11
Name: POTTEIGER WHITE SINK - STAGNANT **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 07:26
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	8.33	ug/L		12/06/23 10:07	1	1.00	12/06/23 10:26	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-12
Name: POTTEIGER WHITE SINK - FLUSH **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 07:27
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 10:28	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GK04047-13
Name: HS NURSE SINK - STAGNANT **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 07:19
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.50	ug/L		12/06/23 10:07	1	1.00	12/06/23 10:30	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-14
Name: HS NURSE SINK - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:20
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.30	ug/L		12/06/23 10:07	1	1.00	12/06/23 10:31	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-15
Name: WF HS HALLWAY WEST - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:29
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.25	ug/L		12/06/23 10:07	1	1.00	12/06/23 10:33	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-16
Name: WF HS HALLWAY WEST - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:30
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.34	ug/L		12/06/23 10:07	1	1.00	12/06/23 10:37	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GK04047-17
Name: WF HS HALLWAY EAST - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:31
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 10:39	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-18
Name: WF HS HALLWAY EAST - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:32
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 10:41	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-19
Name: BF HS HALLWAY EAST - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:32
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 10:42	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-20
Name: BF HS HALLWAY EAST - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:34
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 10:47	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GK04047-21
Name: WF HS GYM - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:35
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 10:48	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-22
Name: WF HS GYM - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:36
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 10:50	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-23
Name: BF HS GYM - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:37
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 10:51	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-24
Name: BF HS GYM - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:38
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 10:56	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GK04047-25
Name: WADE'S RM SINK #1 - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:40
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.41	ug/L		12/06/23 10:07	1	1.00	12/06/23 10:58	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-26
Name: WADE'S RM SINK #1 - FLUSH **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 07:41
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.55	ug/L		12/06/23 10:07	1	1.00	12/06/23 10:59	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-27
Name: WADE'S RM SINK #2 - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:42
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.30	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:01	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-28
Name: WADE'S RM SINK #2 - FLUSH **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 07:43
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:02	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GK04047-29
Name: WADE'S RM SINK #3 - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:43
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.04	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:04	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-30
Name: WADE'S RM SINK #3 - FLUSH **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 07:44
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:09	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-31
Name: WADE'S RM SINK #4 - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:45
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.51	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:10	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-32
Name: WADE'S RM SINK #4 - FLUSH **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 07:46
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:15	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GK04047-33
Name: WF JH NORTH - STAGNANT **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 07:48
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:16	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-34
Name: WF JH NORTH - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:51
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.64	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:18	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-35
Name: BF JH NORTH - STAGNANT **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 07:50
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:20	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-36
Name: BF JH NORTH - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:53
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:21	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GK04047-37
Name: WF JH SOUTH - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:52
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:23	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-38
Name: WF JH SOUTH - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:53
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:24	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-39
Name: LARKIN SINK - STAGNANT **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 07:55
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	4.86	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:26	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-40
Name: LARKIN SINK - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:56
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	11.5	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:34	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GK04047-41
Name: WF FEMA EAST - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 07:59
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:35	KMC	EPA 200.8 REV 5.4

Sample: GK04047-42
Name: WF FEMA EAST - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 08:00
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:37	KMC	EPA 200.8 REV 5.4

Sample: GK04047-43
Name: WF FEMA WEST - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 08:01
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:38	KMC	EPA 200.8 REV 5.4

Sample: GK04047-44
Name: WF FEMA WEST - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 08:02
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:40	KMC	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: GK04047-45
Name: BF FEMA WEST - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 08:03
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:41	KMC	EPA 200.8 REV 5.4

Sample: GK04047-46
Name: BF FEMA WEST - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 08:04
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:43	KMC	EPA 200.8 REV 5.4

Sample: GK04047-47
Name: HS ICE MACHINE - STAGNANT **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 08:10
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:45	KMC	EPA 200.8 REV 5.4

Sample: GK04047-48
Name: HS ICE MACHINE - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 08:11
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:46	KMC	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: GK04047-49
Name: HS KITCHEN TILT SKILLET - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 08:21
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.24	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:48	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-50
Name: HS KITCHEN TILT SKILLET - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 08:22
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:56	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-51
Name: HS KITCHEN SALAD BAR - STAGNANT **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 08:20
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:57	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-52
Name: HS KITCHEN SALAD BAR - FLUSH **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 08:21
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 11:59	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GK04047-53
Name: HS KITCHEN DRY STORAGE - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 08:26
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 12:00	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-54
Name: HS KITCHEN DRY STORAGE - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 08:27
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 12:02	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-55
Name: WF AG BLDG - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 08:47
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 12:03	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-56
Name: WF AG BLDG - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 08:47
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 12:05	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GK04047-57
Name: KECK SINK - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 08:47
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 12:06	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-58
Name: KECK SINK - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 08:49
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 12:11	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-59
Name: BUS BARN SINK - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:53
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/06/23 10:07	1	1.00	12/06/23 12:13	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-60
Name: BUS BARN SINK - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:54
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 16:46	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GK04047-61
Name: BASEBALL CONCESSIONS - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:48
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	12.7	ug/L		12/05/23 11:24	1	1.00	12/05/23 16:47	KMC	EPA 200.8 REV 5.4

Sample: GK04047-62
Name: BASEBALL CONCESSIONS - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:49
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 16:49	KMC	EPA 200.8 REV 5.4

Sample: GK04047-63
Name: FEMA CONCESSIONS - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 08:07
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 16:50	KMC	EPA 200.8 REV 5.4

Sample: GK04047-64
Name: FEMA CONCESSIONS - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 08:08
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 16:52	KMC	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: GK04047-65
Name: PATTEN SINK - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:00
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 16:56	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-66
Name: PATTEN SINK - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:01
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 16:58	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-67
Name: CHAPPELLE SINK - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:10
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.52	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:00	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-68
Name: CHAPPELLE SINK - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:10
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:01	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GK04047-69
Name: TALLEY SINK - STAGNANT **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 09:15
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:03	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-70
Name: TALLEY SINK - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:16
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:07	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-71
Name: WF PREK/K SOUTH - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:03
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:09	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-72
Name: WF PREK/K SOUTH - FLUSH **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 09:04
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:11	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GK04047-73
Name: BF PREK/K SOUTH - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:06
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:15	KMC	EPA 200.8 REV 5.4

Sample: GK04047-74
Name: BF PREK/K SOUTH - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:06
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:17	KMC	EPA 200.8 REV 5.4

Sample: GK04047-75
Name: WF PREK/K NORTH - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:07
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:18	KMC	EPA 200.8 REV 5.4

Sample: GK04047-76
Name: WF PREK/K NORTH - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:08
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:20	KMC	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: GK04047-77
Name: WF ART/MUSIC - STAGNANT **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 09:12
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.47	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:21	KMC	EPA 200.8 REV 5.4

Sample: GK04047-78
Name: WF ART/MUSIC - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:13
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	4.91	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:23	KMC	EPA 200.8 REV 5.4

Sample: GK04047-79
Name: WF LOWER HALL SOUTH - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:18
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	4.18	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:25	KMC	EPA 200.8 REV 5.4

Sample: GK04047-80
Name: WF LOWER HALL SOUTH - FLUSH **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 09:18
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	5.34	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:29	KMC	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: GK04047-81
Name: WF LOWER HALL NORTH - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:20
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:34	KMC	EPA 200.8 REV 5.4

Sample: GK04047-82
Name: WF LOWER HALL NORTH - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:21
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:36	KMC	EPA 200.8 REV 5.4

Sample: GK04047-83
Name: BF LOWER HALL NORTH - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:22
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:37	KMC	EPA 200.8 REV 5.4

Sample: GK04047-84
Name: BF LOWER HALL NORTH - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:23
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:39	KMC	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: GK04047-85
Name: ES ICE MACHINE - STAGNANT **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 09:26
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:40	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-86
Name: ES ICE MACHINE - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:28
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:42	KMC	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-87
Name: WF UPPER HALL SOUTH - STAGNANT **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 09:29
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.33	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:43	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GK04047-88
Name: WF UPPER HALL SOUTH - FLUSH **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 09:30
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.98	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:45	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: GK04047-89
Name: WF UPPER HALL CENTER - STAGNANT **Matrix:**
Drinking Water - Grab

Sampled: 11/18/23 09:37
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:46	KMC	EPA 200.8 REV 5.4

Sample: GK04047-90
Name: WF UPPER HALL CENTER - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:38
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:54	KMC	EPA 200.8 REV 5.4

Sample: GK04047-91
Name: WF UPPER HALL NORTH - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:32
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:56	KMC	EPA 200.8 REV 5.4

Sample: GK04047-92
Name: WF UPPER HALL NORTH - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:33
Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:57	KMC	EPA 200.8 REV 5.4



ANALYTICAL RESULTS

Sample: GK04047-93

Name: BF UPPER HALL NORTH - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:34

Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 17:59	KMC	EPA 200.8 REV 5.4

Sample: GK04047-94

Name: BF UPPER HALL NORTH - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:35

Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		12/05/23 11:24	1	1.00	12/05/23 18:01	KMC	EPA 200.8 REV 5.4

Sample: GK04047-95

Name: ES KITCHEN SINK - STAGNANT
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:40

Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.53	ug/L		12/05/23 11:24	1	1.00	12/05/23 18:02	KMC	EPA 200.8 REV 5.4

Sample: GK04047-96

Name: ES KITCHEN SINK - FLUSH
Matrix: Drinking Water - Grab

Sampled: 11/18/23 09:41

Received: 11/22/23 14:45

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.48	ug/L		12/05/23 11:24	1	1.00	12/05/23 18:04	KMC	EPA 200.8 REV 5.4



Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279
Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807 USEPA

DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389 TNI

Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050

Certified by: Chenise Lambert-Sykes, Project Manager



ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

[illegible]

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDO	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

CLIENT 1 Laclede County R-1 School District ADDRESS 726 W. Jefferson CITY Conway, MO 65632 CONTACT/PERSON Matthew Searson		PROJECT LOCATION PROJECT NUMBER 417-597-5269 PHONE NUMBER 417-597-5269 E-MAIL msearson@lcr1.org		PURCHASE ORDER # ANALYSIS REQUESTED 3 DW Lead (Pb) ☒ Turb Check ☒		(FOR LAB USE ONLY) 4 LOGIN # GK04047 LOGGED BY: CLIENT: Laclede County R-1 School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: REMARKS # of Containers Requested: 96	
SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT) Potteiger White Sink - Flush HS Nurse Sink - Stagnant HS Nurse Sink - Flush WF HS Hallway - West - Stagnant WF HS Hallway - West - Flush WF HS Hallway - East - Stagnant WF HS Hallway - East - Flush BF HS Hallway - East - Stagnant BF HS Hallway - East - Flush WF HS Gym - Stagnant WF HS Gym - Flush		DATE COLLECTED 11/19/23 7:27 7:19 7:20 7:29 7:30 7:31 7:32 7:32 7:34 7:35 7:36		SAMPLE TYPE GRAB ☒ COMPOSITE ☐ MATRIX TYPE WW-WASTEWATER DW-DRINKING WATER GW-GROUNDWATER WWEL-SEWAGE WAF-WASTEWATER WAF-ADJACENT SOIL WAF-ADJACENT SOIL WAF-ADJACENT SOIL		BOTTLE COUNT PRES CODE CURF PROVIDED	
CHEMICAL PRESERVATION CODES: 1-HCL 2-H2SO4 3-HNO3 4-NAOH 5-NA2S2O3 6-UNPRESERVED 7-OTHER		DATE RESULTS NEEDED 5		I understand that by initiating this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.		PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS)	
RELINQUISHED BY: (SIGNATURE) DATE 11-22-23 TIME 1445		RECEIVED BY: (SIGNATURE) DATE 11-22-23 TIME 1445		COMMENTS: (FOR LAB USE ONLY) 8		SAMPLE TEMPERATURE UPON RECEIPT 17.0 °C CHILL PROCESS STARTED PRIOR TO RECEIPT YOR YOR SAMPLE(S) RECEIVED ON ICE YOR YOR SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED YOR YOR DATE AND TIME TAKEN FROM SAMPLE BOTTLE	

REGULATORY PROGRAM (CIRCLE):	NPDES
MORSCA	RCRA
CDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

CLIENT Laclede County R-1 School District ADDRESS 726 W. Jefferson CITY STATE ZIP Conway, MO 65632 CONTACT PERSON Matthew Searson		PROJECT LOCATION PROJECT NUMBER 417-597-5269 PHONE NUMBER 417-597-5269 E-MAIL msearson@lcr1.org		PURCHASE ORDER # DATE SHIPPED MATRIX TYPES: WW-WASTEWATER SW-SURFACE WATER GW-GROUNDWATER WWSL-SLUDGE MSL-MONITORING STATION MSL-ADJUTANT MSL-ADJUTANT SOL-SOLID		ANALYSIS REQUESTED DW Lead (Pb) Turb Check		LOGGED BY: GKD4047 CLIENT: Laclede County R-1 School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____					
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT) RF H.S. Gym - Stagnant RF H.S. Gym - Flush Wade's Rm Sink #1 - Stagnant Wade's Rm Sink #1 - Flush Wade's Rm Sink #2 - Stagnant Wade's Rm Sink #2 - Flush Wade's Rm Sink #3 - Stagnant Wade's Rm Sink #3 - Flush Wade's Rm Sink #4 - Stagnant Wade's Rm Sink #4 - Flush WF J.H. NASH - Stagnant		DATE COLLECTED 11/19/23 7:37 7:38 7:40 7:41 7:42 7:43 7:43 7:44 7:45 7:46 7:48		SAMPLE TYPE COMP GRAB ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓		MATRIX TYPE TYPE _____ _____ _____ _____ _____ _____ _____ _____ _____ _____ _____		BOTTLE COUNT _____ _____ _____ _____ _____ _____ _____ _____ _____ _____ _____		PRES CODE CLIENT PROVIDED _____ _____ _____ _____ _____ _____ _____ _____ _____ _____ _____		REMARKS # of Containers Requested: 96	
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		DATE 11-22-23 TIME 1120		DATE 11-22-23 TIME 1120		DATE 11/22/27 TIME 1445		COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT 17.0 °C CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED DATE AND TIME TAKEN FROM SAMPLE BOTTLE 1445					

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

Pace
 Pace Analytical Services
 WWW.PACELABS.COM

CLIENT		PROJECT LOCATION		PURCHASE ORDER #		ANALYSIS REQUESTED		(FOR LAB USE ONLY)	
1	2	3	4	5	6	7	8	9	10
Laclede County R-1 School District 726 W. Jefferson Conway, MO 65632		PHONE NUMBER 417-597-5269		E-MAIL msearson@lcr1.org		DATE SHIPPED _____		LOGGED BY: Laclede County R-1 School District	
CITY Conway, MO		SAMPLER (PLEASE PRINT) John Boyles		MATRIX TYPE: WW-WASTEWATER DW-DRINKING WATER GW-GROUNDWATER SW-SURFACE WATER ML-NON-AQUEOUS SOLID LGT-LEACHATE OIL-SOL SOL-SOLID		PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes GUSTODY SEAL #:		LOGIN #: GKO4047	
CONTACT PERSON Matthew Searson		SAMPLER'S SIGNATURE 		DATE COLLECTED 11/18/23		BOTTLE COUNT _____		REMARKS # of Containers Requested: 96	
2		3		4		5		6	
SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE		PRES CODE PROVIDED	
WF J.H. North - Flush		11/18/23		7:51		✓		DW Lead (Pb)	
BF J.H. North - Stagnant		7:52		7:53		✓		Turb Check	
BF J.H. North - Flush		7:53		7:54		✓			
WF J.H. South - Stagnant		7:54		7:55		✓			
WF J.H. South - Flush		7:55		7:56		✓			
Larkin Sink - Stagnant		7:56		7:57		✓			
Larkin Sink - Flush		7:57		7:58		✓			
WF FEMA East - Stagnant		7:59		8:00		✓			
WF FEMA East - Flush		8:00		8:01		✓			
WF FEMA West - Stagnant		8:01		8:02		✓			
WF FEMA West - Flush		8:02		8:03		✓			
CHEMICAL PRESERVATION CODES:		1-HCL		2-H2SO4		3-HNO3		4-NAOH	
		5-NA2S2O3		6-UNPRESERVED		7-OTHER			
TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH RESULTS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		RUSH		DATE RESULTS NEEDED		5		I understand that by initiating this box I give the lab permission to proceed with analysis, even though it may not meet all sample containment requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.	
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE		RUSH		DATE RESULTS NEEDED		5		PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS)	
EMAIL IF DIFFERENT FROM ABOVE: PHONE IF DIFFERENT FROM ABOVE:		RUSH		DATE RESULTS NEEDED		5		PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS)	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		8		COMMENTS: (FOR LAB USE ONLY)	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		8		SAMPLE TEMPERATURE UPON RECEIPT 17.0 °C	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		8		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N Y OR N Y OR N	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		8		SAMPLE RECEIVED ON ICE Y OR N Y OR N Y OR N	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		8		SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N Y OR N Y OR N	
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		8		DATE AND TIME TAKEN FROM SAMPLE BOTTLE	

CHAIN OF CUSTODY RECORD

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

[illegible]

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

Pace Pace Analytical Services
WWW.PACELABS.COM

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

CLIENT 1 Laclede County R-1 School District ADDRESS 726 W. Jefferson CITY STATE ZIP Conway, MO 65632 CONTACT PERSON Matthew Searson		PROJECT LOCATION PROJECT NUMBER 417-597-5269 PHONE NUMBER 417-597-5269 E-MAIL msearson@lcr1.org		DATE SHIPPED DATE SHIPPED		ANALYSIS REQUESTED 3 DW Lead (Pb) ☒ Turb Check ☒		(FOR LAB USE ONLY) 4 LOGIN # GK04047 LOGGED BY: Laclede County R-1 School District CLIENT: Laclede County R-1 School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #:	
2 SAMPLE DESCRIPTION: (INCLUDE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED TIME COLLECTED SAMPLE TYPE GRAB		MATRIX TYPE MATRIX COUNT PRES CODE CLIENT PROVIDED		REMARKS # of Containers Requested: 96			
WF AG Bldg - Flush		11/18/23 8:47							
Keeck sink - stagnant		8:47							
Keeck sink - Flush		8:49							
Bos Barn sink - Stagnant		9:53							
Bos Barn sink - Flush		9:54							
Basketball concessions - Stagnant		10:48							
Basketball concessions - Flush		11:49							
FEMA concessions - Stagnant		12:07							
FEMA concessions - Flush		12:08							
Patten Sink - Stagnant		9:00							
Patten Sink - Flush		9:01							
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER		DATE RESULTS NEEDED		8		I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.	
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE		EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		RECEIVED BY: (SIGNATURE) DATE TIME		RECEIVED BY: (SIGNATURE) DATE TIME		COMMENTS: (FOR LAB USE ONLY)	
RELINQUISHED BY: (SIGNATURE) DATE TIME		RELINQUISHED BY: (SIGNATURE) DATE TIME		RELINQUISHED BY: (SIGNATURE) DATE TIME		RELINQUISHED BY: (SIGNATURE) DATE TIME		SAMPLE TEMPERATURE UPON RECEIPT 17.0 °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT Y OR N REPORT IS NEEDED	

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Laclede County R-1 School District ADDRESS 726 W. Jefferson CITY STATE ZIP Conway, MO 65632 CONTACT PERSON Matthew Searson		2 ANALYSIS REQUESTED DW Lead (Pb) ☒ Turb Check ☒		3 ANALYSIS REQUESTED (FOR LAB USE ONLY) LOGIN # <u>GK04047</u> LOGGED BY: CLIENT: Laclede County R-1 School District PROJECT: Drinking Water Lead PROJ. MGR.: Cherise Lambert-Sykes CUSTODY SEAL #: REMARKS # of Containers Requested: 96	
4 PROJECT INFORMATION PROJECT NUMBER: 417-597-5269 PHONE NUMBER: 417-597-5269 E-MAIL: msearson@lcr1.org DATE SHIPPED:		5 MATRIX TYPES: WW-WASTEWATER DW-DRINKING WATER GW-GROUNDWATER WWSW-WASTEWATER WWSW-SOLID WWSW-LIQUID WWSW-NON AQUEOUS SOLID WWSW-LEACHATE WWSW-SOL-SOLID		6 PRES CODE CLIENT PROVIDED	
7 DATE COLLECTED 11/13/23		8 SAMPLE TYPE COMP		9 MATRIX TYPE COMP	
10 DATE COLLECTED 11/13/23		11 TIME COLLECTED 9:10		12 BOTTLE COUNT 1	
13 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT) Chappelle Sink - stagnant		14 DATE COLLECTED 11/13/23		15 TIME COLLECTED 9:10	
Chappelle Sink - Flush		9:10		1	
Talley Sink - stagnant		9:15		1	
Talley Sink - Flush		9:16		1	
WF Pre K/K South - stagnant		9:03		1	
WF Pre K/K South - Flush		9:04		1	
BF Pre K/K South - stagnant		9:06		1	
BF Pre K/K South - Flush		9:06		1	
WF Pre K/K North - stagnant		9:07		1	
WF Pre K/K North - Flush		9:08		1	
WF Art Music - stagnant		9:12		1	
16 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL ☒ RUSH		17 DATE RESULTS NEEDED		18 DATE 11-22-23	
19 RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		20 RECEIVED BY: (SIGNATURE) [Signature]		21 DATE 11-22-23	
22 RELINQUISHED BY: (SIGNATURE) [Signature]		23 RECEIVED BY: (SIGNATURE) [Signature]		24 DATE 11-22-23	
25 RELINQUISHED BY: (SIGNATURE) [Signature]		26 RECEIVED BY: (SIGNATURE) [Signature]		27 DATE 11-22-23	
28 RELINQUISHED BY: (SIGNATURE) [Signature]		29 RECEIVED BY: (SIGNATURE) [Signature]		30 DATE 11-22-23	
31 RELINQUISHED BY: (SIGNATURE) [Signature]		32 RECEIVED BY: (SIGNATURE) [Signature]		33 DATE 11-22-23	
34 RELINQUISHED BY: (SIGNATURE) [Signature]		35 RECEIVED BY: (SIGNATURE) [Signature]		36 DATE 11-22-23	
37 RELINQUISHED BY: (SIGNATURE) [Signature]		38 RECEIVED BY: (SIGNATURE) [Signature]		39 DATE 11-22-23	
40 RELINQUISHED BY: (SIGNATURE) [Signature]		41 RECEIVED BY: (SIGNATURE) [Signature]		42 DATE 11-22-23	
43 RELINQUISHED BY: (SIGNATURE) [Signature]		44 RECEIVED BY: (SIGNATURE) [Signature]		45 DATE 11-22-23	
46 RELINQUISHED BY: (SIGNATURE) [Signature]		47 RECEIVED BY: (SIGNATURE) [Signature]		48 DATE 11-22-23	
49 RELINQUISHED BY: (SIGNATURE) [Signature]		50 RECEIVED BY: (SIGNATURE) [Signature]		51 DATE 11-22-23	
52 RELINQUISHED BY: (SIGNATURE) [Signature]		53 RECEIVED BY: (SIGNATURE) [Signature]		54 DATE 11-22-23	
55 RELINQUISHED BY: (SIGNATURE) [Signature]		56 RECEIVED BY: (SIGNATURE) [Signature]		57 DATE 11-22-23	
58 RELINQUISHED BY: (SIGNATURE) [Signature]		59 RECEIVED BY: (SIGNATURE) [Signature]		60 DATE 11-22-23	
61 RELINQUISHED BY: (SIGNATURE) [Signature]		62 RECEIVED BY: (SIGNATURE) [Signature]		63 DATE 11-22-23	
64 RELINQUISHED BY: (SIGNATURE) [Signature]		65 RECEIVED BY: (SIGNATURE) [Signature]		66 DATE 11-22-23	
67 RELINQUISHED BY: (SIGNATURE) [Signature]		68 RECEIVED BY: (SIGNATURE) [Signature]		69 DATE 11-22-23	
70 RELINQUISHED BY: (SIGNATURE) [Signature]		71 RECEIVED BY: (SIGNATURE) [Signature]		72 DATE 11-22-23	
73 RELINQUISHED BY: (SIGNATURE) [Signature]		74 RECEIVED BY: (SIGNATURE) [Signature]		75 DATE 11-22-23	
76 RELINQUISHED BY: (SIGNATURE) [Signature]		77 RECEIVED BY: (SIGNATURE) [Signature]		78 DATE 11-22-23	
79 RELINQUISHED BY: (SIGNATURE) [Signature]		80 RECEIVED BY: (SIGNATURE) [Signature]		81 DATE 11-22-23	
82 RELINQUISHED BY: (SIGNATURE) [Signature]		83 RECEIVED BY: (SIGNATURE) [Signature]		84 DATE 11-22-23	
85 RELINQUISHED BY: (SIGNATURE) [Signature]		86 RECEIVED BY: (SIGNATURE) [Signature]		87 DATE 11-22-23	
88 RELINQUISHED BY: (SIGNATURE) [Signature]		89 RECEIVED BY: (SIGNATURE) [Signature]		90 DATE 11-22-23	
91 RELINQUISHED BY: (SIGNATURE) [Signature]		92 RECEIVED BY: (SIGNATURE) [Signature]		93 DATE 11-22-23	
94 RELINQUISHED BY: (SIGNATURE) [Signature]		95 RECEIVED BY: (SIGNATURE) [Signature]		96 DATE 11-22-23	
97 RELINQUISHED BY: (SIGNATURE) [Signature]		98 RECEIVED BY: (SIGNATURE) [Signature]		99 DATE 11-22-23	
100 RELINQUISHED BY: (SIGNATURE) [Signature]		101 RECEIVED BY: (SIGNATURE) [Signature]		102 DATE 11-22-23	
103 RELINQUISHED BY: (SIGNATURE) [Signature]		104 RECEIVED BY: (SIGNATURE) [Signature]		105 DATE 11-22-23	
106 RELINQUISHED BY: (SIGNATURE) [Signature]		107 RECEIVED BY: (SIGNATURE) [Signature]		108 DATE 11-22-23	
109 RELINQUISHED BY: (SIGNATURE) [Signature]		110 RECEIVED BY: (SIGNATURE) [Signature]		111 DATE 11-22-23	
112 RELINQUISHED BY: (SIGNATURE) [Signature]		113 RECEIVED BY: (SIGNATURE) [Signature]		114 DATE 11-22-23	
115 RELINQUISHED BY: (SIGNATURE) [Signature]		116 RECEIVED BY: (SIGNATURE) [Signature]		117 DATE 11-22-23	
118 RELINQUISHED BY: (SIGNATURE) [Signature]		119 RECEIVED BY: (SIGNATURE) [Signature]		120 DATE 11-22-23	
121 RELINQUISHED BY: (SIGNATURE) [Signature]		122 RECEIVED BY: (SIGNATURE) [Signature]		123 DATE 11-22-23	
124 RELINQUISHED BY: (SIGNATURE) [Signature]		125 RECEIVED BY: (SIGNATURE) [Signature]		126 DATE 11-22-23	
127 RELINQUISHED BY: (SIGNATURE) [Signature]		128 RECEIVED BY: (SIGNATURE) [Signature]		129 DATE 11-22-23	
130 RELINQUISHED BY: (SIGNATURE) [Signature]		131 RECEIVED BY: (SIGNATURE) [Signature]		132 DATE 11-22-23	
133 RELINQUISHED BY: (SIGNATURE) [Signature]		134 RECEIVED BY: (SIGNATURE) [Signature]		135 DATE 11-22-23	
136 RELINQUISHED BY: (SIGNATURE) [Signature]		137 RECEIVED BY: (SIGNATURE) [Signature]		138 DATE 11-22-23	
139 RELINQUISHED BY: (SIGNATURE) [Signature]		140 RECEIVED BY: (SIGNATURE) [Signature]		141 DATE 11-22-23	
142 RELINQUISHED BY: (SIGNATURE) [Signature]		143 RECEIVED BY: (SIGNATURE) [Signature]		144 DATE 11-22-23	
145 RELINQUISHED BY: (SIGNATURE) [Signature]		146 RECEIVED BY: (SIGNATURE) [Signature]		147 DATE 11-22-23	
148 RELINQUISHED BY: (SIGNATURE) [Signature]		149 RECEIVED BY: (SIGNATURE) [Signature]		150 DATE 11-22-23	
151 RELINQUISHED BY: (SIGNATURE) [Signature]		152 RECEIVED BY: (SIGNATURE) [Signature]		153 DATE 11-22-23	
154 RELINQUISHED BY: (SIGNATURE) [Signature]		155 RECEIVED BY: (SIGNATURE) [Signature]		156 DATE 11-22-23	
157 RELINQUISHED BY: (SIGNATURE) [Signature]		158 RECEIVED BY: (SIGNATURE) [Signature]		159 DATE 11-22-23	
160 RELINQUISHED BY: (SIGNATURE) [Signature]		161 RECEIVED BY: (SIGNATURE) [Signature]		162 DATE 11-22-23	
163 RELINQUISHED BY: (SIGNATURE) [Signature]		164 RECEIVED BY: (SIGNATURE) [Signature]		165 DATE 11-22-23	
166 RELINQUISHED BY: (SIGNATURE) [Signature]		167 RECEIVED BY: (SIGNATURE) [Signature]		168 DATE 11-22-23	
169 RELINQUISHED BY: (SIGNATURE) [Signature]		170 RECEIVED BY: (SIGNATURE) [Signature]		171 DATE 11-22-23	
172 RELINQUISHED BY: (SIGNATURE) [Signature]		173 RECEIVED BY: (SIGNATURE) [Signature]		174 DATE 11-22-23	
175 RELINQUISHED BY: (SIGNATURE) [Signature]		176 RECEIVED BY: (SIGNATURE) [Signature]		177 DATE 11-22-23	
178 RELINQUISHED BY: (SIGNATURE) [Signature]		179 RECEIVED BY: (SIGNATURE) [Signature]		180 DATE 11-22-23	
181 RELINQUISHED BY: (SIGNATURE) [Signature]		182 RECEIVED BY: (SIGNATURE) [Signature]		183 DATE 11-22-23	
184 RELINQUISHED BY: (SIGNATURE) [Signature]		185 RECEIVED BY: (SIGNATURE) [Signature]		186 DATE 11-22-23	
187 RELINQUISHED BY: (SIGNATURE) [Signature]		188 RECEIVED BY: (SIGNATURE) [Signature]		189 DATE 11-22-23	
190 RELINQUISHED BY: (SIGNATURE) [Signature]		191 RECEIVED BY: (SIGNATURE) [Signature]		192 DATE 11-22-23	
193 RELINQUISHED BY: (SIGNATURE) [Signature]		194 RECEIVED BY: (SIGNATURE) [Signature]		195 DATE 11-22-23	
196 RELINQUISHED BY: (SIGNATURE) [Signature]		197 RECEIVED BY: (SIGNATURE) [Signature]		198 DATE 11-22-23	
199 RELINQUISHED BY: (SIGNATURE) [Signature]		200 RECEIVED BY: (SIGNATURE) [Signature]		201 DATE 11-22-23	
202 RELINQUISHED BY: (SIGNATURE) [Signature]		203 RECEIVED BY: (SIGNATURE) [Signature]		204 DATE 11-22-23	
205 RELINQUISHED BY: (SIGNATURE) [Signature]		206 RECEIVED BY: (SIGNATURE) [Signature]		207 DATE 11-22-23	
208 RELINQUISHED BY: (SIGNATURE) [Signature]		209 RECEIVED BY: (SIGNATURE) [Signature]		210 DATE 11-22-23	
211 RELINQUISHED BY: (SIGNATURE) [Signature]		212 RECEIVED BY: (SIGNATURE) [Signature]		213 DATE 11-22-23	
214 RELINQUISHED BY: (SIGNATURE) [Signature]		215 RECEIVED BY: (SIGNATURE) [Signature]		216 DATE 11-22-23	
217 RELINQUISHED BY: (SIGNATURE) [Signature]		218 RECEIVED BY: (SIGNATURE) [Signature]		219 DATE 11-22-23	
220 RELINQUISHED BY: (SIGNATURE) [Signature]		221 RECEIVED BY: (SIGNATURE) [Signature]		222 DATE 11-22-23	
223 RELINQUISHED BY: (SIGNATURE) [Signature]		224 RECEIVED BY: (SIGNATURE) [Signature]		225 DATE 11-22-23	
226 RELINQUISHED BY: (SIGNATURE) [Signature]		227 RECEIVED BY: (SIGNATURE) [Signature]		228 DATE 11-22-23	
229 RELINQUISHED BY: (SIGNATURE) [Signature]		230 RECEIVED BY: (SIGNATURE) [Signature]		231 DATE 11-22-23	
232 RELINQUISHED BY: (SIGNATURE) [Signature]		233 RECEIVED BY: (SIGNATURE) [Signature]		234 DATE 11-22-23	
235 RELINQUISHED BY: (SIGNATURE) [Signature]		236 RECEIVED BY: (SIGNATURE) [Signature]		237 DATE 11-22-23	
238 RELINQUISHED BY: (SIGNATURE) [Signature]		239 RECEIVED BY: (SIGNATURE) [Signature]		240 DATE 11-22-23	
241 RELINQUISHED BY: (SIGNATURE) [Signature]		242 RECEIVED BY: (SIGNATURE) [Signature]		243 DATE 11-22-23	
244 RELINQUISHED BY: (SIGNATURE) [Signature]		245 RECEIVED BY: (SIGNATURE) [Signature]		246 DATE 11-22-23	
247 RELINQUISHED BY: (SIGNATURE) [Signature]		248 RECEIVED BY: (SIGNATURE) [Signature]		249 DATE 11-22-23	
250 RELINQUISHED BY: (SIGNATURE) [Signature]		251 RECEIVED BY: (SIGNATURE) [Signature]		252 DATE 11-22-23	
253 RELINQUISHED BY: (SIGNATURE) [Signature]		254 RECEIVED BY: (SIGNATURE) [Signature]		255 DATE 11-22-23	
256 RELINQUISHED BY: (SIGNATURE) [Signature]		257 RECEIVED BY: (SIGNATURE) [Signature]		258 DATE 11-22-23	
259 RELINQUISHED BY: (SIGNATURE) [Signature]		260 RECEIVED BY: (SIGNATURE) [Signature]		261 DATE 11-22-23	
262 RELINQUISHED BY: (SIGNATURE) [Signature]		263 RECEIVED BY: (SIGNATURE) [Signature]		264 DATE 11-22-23	
265 RELINQUISHED BY: (SIGNATURE) [Signature]		266 RECEIVED BY: (SIGNATURE) [Signature]		267 DATE 11-22-23	
268 RELINQUISHED BY: (SIGNATURE) [Signature]		269 RECEIVED BY: (SIGNATURE) [Signature]		270 DATE 11-22-23	
271 RELINQUISHED BY: (SIGNATURE) [Signature]		272 RECEIVED BY: (SIGNATURE) [Signature]		273 DATE 11-22-23	
274 RELINQUISHED BY: (SIGNATURE) [Signature]		275 RECEIVED BY: (SIGNATURE) [Signature]		276 DATE 11-22-23	
277 RELINQUISHED BY: (SIGNATURE) [Signature]		278 RECEIVED BY: (SIGNATURE) [Signature]		279 DATE 11-22-23	
280 RELINQUISHED BY: (SIGNATURE) [Signature]		281 RECEIVED BY: (SIGNATURE) [Signature]		282 DATE 11-22-23	
283 RELINQUISHED BY: (SIGNATURE) [Signature]		284 RECEIVED BY: (SIGNATURE) [Signature]		285 DATE 11-22-23	
286 RELINQUISHED BY: (SIGNATURE) [Signature]		287 RECEIVED BY: (SIGNATURE) [Signature]		288 DATE 11-22-23	
289 RELINQUISHED BY: (SIGNATURE) [Signature]		290 RECEIVED BY: (SIGNATURE) [Signature]		291 DATE 11-22-23	
292 RELINQUISHED BY: (SIGNATURE) [Signature]		293 RECEIVED BY: (SIGNATURE) [Signature]		294 DATE 11-22-23	
295 RELINQUISHED BY: (SIGNATURE) [Signature]		296 RECEIVED BY: (SIGNATURE) [Signature]		297 DATE 11-22-23	
298 RELINQUISHED BY: (SIGNATURE) [Signature]		299 RECEIVED BY: (SIGNATURE) [Signature]		300 DATE 11-22-23	
299 RELINQUISHED BY: (SIGNATURE) [Signature]		300 RECEIVED BY: (SIGNATURE) [Signature]		301 DATE 11-22-23	
300 RELINQUISHED BY: (SIGNATURE) [Signature]					

REGULATORY PROGRAM (CIRCLE):
MORBCA
CCDD

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

CLIENT		PROJECT LOCATION		PURCHASE ORDER #		ANALYSIS REQUESTED		(FOR LAB USE ONLY)	
ADDRESS		PHONE NUMBER		E-MAIL		DATE SHIPPED		LOGGED BY:	
CITY/STATE/ZIP		SAMPLER (PLEASE PRINT)		SAMPLER'S SIGNATURE		MATRIX TYPES:		CLIENT:	
CONTACT PERSON		DATE COLLECTED		TIME COLLECTED		BOTTLE COUNT		PROJECT:	
SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED		TIME COLLECTED		BOTTLE COUNT		PROJ. MGR.:	
CHEMICAL PRESERVATION CODES:		DATE COLLECTED		TIME COLLECTED		BOTTLE COUNT		CUSTODY SEAL #:	
WF ARI/MUSIC - Flush	11/18/23	915	✓						
WF Lower Hall South - Stagnant	918	✓							
WF Lower Hall South - Flush	918	✓							
WF Lower Hall North - Stagnant	920	✓							
WF Lower Hall North - Flush	921	✓							
BF Lower Hall North - Stagnant	922	✓							
BF Lower Hall North - Flush	923	✓							
ES, ICE Machine - Stagnant	926	✓							
ES, ICE Machine - Flush	928	✓							
WF Upper Hall South - Stagnant	929	✓							
WF Upper Hall South - Flush	930	✓							

TURNAROUND TIME REQUESTED (PLEASE CIRCLE)		DATE RESULTS NEEDED		PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS)	
RUSH TATIS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE		DATE RESULTS NEEDED		DATE	
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE		DATE RESULTS NEEDED		TIME	
NORMAL		DATE		DATE	
RUSH		TIME		TIME	

RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
DATE		DATE		DATE	
TIME		TIME		TIME	
DATE 11-22-23		DATE 11-22-23		DATE 11-22-23	
TIME 1445		TIME 1120		TIME 1445	

RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
DATE		DATE		DATE	
TIME		TIME		TIME	
DATE 11-22-23		DATE 11-22-23		DATE 11-22-23	
TIME 1445		TIME 1120		TIME 1445	

RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
DATE		DATE		DATE	
TIME		TIME		TIME	
DATE 11-22-23		DATE 11-22-23		DATE 11-22-23	
TIME 1445		TIME 1120		TIME 1445	

RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
DATE		DATE		DATE	
TIME		TIME		TIME	
DATE 11-22-23		DATE 11-22-23		DATE 11-22-23	
TIME 1445		TIME 1120		TIME 1445	

RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
DATE		DATE		DATE	
TIME		TIME		TIME	
DATE 11-22-23		DATE 11-22-23		DATE 11-22-23	
TIME 1445		TIME 1120		TIME 1445	

RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
DATE		DATE		DATE	
TIME		TIME		TIME	
DATE 11-22-23		DATE 11-22-23		DATE 11-22-23	
TIME 1445		TIME 1120		TIME 1445	

RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
DATE		DATE		DATE	
TIME		TIME		TIME	
DATE 11-22-23		DATE 11-22-23		DATE 11-22-23	
TIME 1445		TIME 1120		TIME 1445	

RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
DATE		DATE		DATE	
TIME		TIME		TIME	
DATE 11-22-23		DATE 11-22-23		DATE 11-22-23	
TIME 1445		TIME 1120		TIME 1445	

RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	
DATE		DATE		DATE	
TIME		TIME		TIME	
DATE 11-22-23		DATE 11-22-23		DATE 11-22-23	
TIME 1445		TIME 1120		TIME 1445	

RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)	

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

STATE WHERE SAMPLE COLLECTED

Pace
Pace Analytical Services
WWW.PACELABS.COM

[illegible]